DATA SHEET
SV-ACCCT-100-UT-B

SEVR
sevr.com.au
Version 3

CT CLAMP







Technical Information

	SV-ACCCT-100-UT-B
Rated Primary Current	100A
Saturation Current	>120A
Rated Secondary Current	50mA
Accuracy	1% (5A - 120A)
Operating Frequency	50/60Hz
Load Resistance	10 Ω
Compatible With	X1 Charger - SV-EVX1-7T-1P
Cable Length	15m

Installation Guide

1. CT clamp installed on incoming mains




CT Meter Connection


2. Direction Arrow



2. CT Meter Load Limit Adjustments



CT Adjustments



No real time CT readings

The information contained in this document is the sole property of SEVR. Any reproduction in part or as a while without written permission of SEVR is prohibited